

August 28, 2023

## BID CLARIFICATION No. 1

### **RE: Invitation to Provide Bid for Construction Services Ionia Transportation Facility Door & Lintel Replacement**

**Location:** 251 East Adams Street, Ionia Michigan 48846

**Owner's Representative:** Heidi Wenzel, City of Ionia Director of Transportation

**Architect:** Gregg Yeomans RA, Fishbeck

The following three clarifications are to be considered part of the Bid Documents.

Point #1-

See Miscellaneous Work on Page 3 of the Invitation to Bid. The exit signs above the doors, on the interior walls, are to be reinstalled where they currently are positioned. This is typically the second course of block above the door head.

Point #2-

See Conceptual Detail of New Lintel on Page 3 of the Invitation to Bid. The section detail shows  $3\frac{1}{2} \times 3\frac{1}{2} \times \frac{1}{2}$  angles.  $4 \times 4 \times \frac{3}{8}$  angles may be used with an 8-gauge plate. This will allow hot dipped galvanized members to be used. It will be determined at the time of demolition if any change to the new sizes given here will be required.

Point #3-

See Certificate of Compliance with Federal Contract Clauses, the last page of the Invitation to Bid. There is a line for an Authorization Number. This should be left blank when this page is submitted with the bid.

End of Clarifications